

Investigation of Artificial Intelligence Approaches Capablity in Predicting the WasteWater Treatment Plant Performance (Case Study: Tabriz WasteWater Treatment Plant)

MohammadTaghi Aalami^{a1}, Nasim Hejabi^a, Vahid Nourani^a, Seyed Mahdi Saghebian^b

^a Department of Civil Engineering, Faculty of Civil Engineering, University of Tabriz, Tabriz- Iran

^b Department of Civil Engineering, Ahar Branch, Islamic Azad University, Ahar- Iran

Abstract:

Due to the excessive concern about environmental issues, researchers had to come up with a better solution to control the WasteWater treatment plants (WWTPS). In this research, two approaches, including Artificial Neural Network (ANN) and Support Vector Machine (SVM) have been used for modeling effluent quality of Tabriz WasteWater Treatment Plant. Input data of models consist of BOD_{inf} , COD_{inf} , TSS_{inf} and PH_{inf} of influent sewage related to Tabriz Treatment Plant which have been used to predict the corresponding value of BOD_{eff} , COD_{eff} and TSS_{eff} concerning the treatment plant effluent. The daily, weekly and monthly average data have been studied. According to results, two approaches mentioned, have the best performance in the prediction of the monthly average dataset of effluent parameters of Tabriz WasteWater Treatment Plant.

Keywords:

WasteWater Treatment Plant, Artificial Intelligence Models, Artificial Neural Network, Support Vector Machine, Effluent quality of Wastewater Treatment Plant.

1-Introduction:

Rapid urban development in residential and urban areas has created a heavy burden on the environment, which is often of less importance for economic and industrial development, especially in developed countries [1]. Increasing concern over environmental issues has encouraged researchers to focus their attention on the proper performance and control of Wastewater treatment plants (WWTPS) [2], [3]. Considering as the number of wastewater treatment plants and their importance increased day by day, the prediction and the analysis of the pollutant parameters based on new methods are necessary [4].

Operation and safe control of a wastewater treatment plant can be achieved by developing a modeling tool in predicting the wastewater treatment plant performance based on past observations of key parameters of the quality. The wastewater treatment plant contains of several complex processes such as physical, biological and chemical processes. Most of these processes exhibit nonlinear behaviors which is difficult to describe with linear mathematical models [3]. Therefore, artificial intelligence techniques have been developed as an alternative to these mathematical models [4]. Due to the complexity of estimating the quality parameters of the treatment process and their relation, in the present study, artificial neural network and support vector machine have been used to model the behavior of Tabriz wastewater treatment plant. In recent years, many studies have been carried out to assess the behavior of Wastewater Treatment Plant by using the Artificial Intelligence methods. Hamed et al. (2004) used Neural network models in predicting daily concentration of BOD_{eff} and SS_{eff} parameters at Siro Wastewater Treatment Plant in Egypt [5]. Turkmenler and Pala (2017) developed Artificial Neural Network Techniques (ANN) to predict the BOD_{eff} of Wastewater Treatment Plant in Turkey [4]. Nourani et al. (2018) offered FFNN, ANFIS, SVM, MLR and Simple Averaging Ensemble (SAE), Weighted Averaging Ensemble (WAE) and Neural Network Ensemble (NNE) techniques to increase the performance of single models, to predict BOD_{eff} , COD_{eff} , and TN_{eff} of the Nicosia Wastewater Treatment Plant in Cyprus [6]. According the high ability of Artificial Intelligence techniques, it is assumed that these methods can appropriately predict the effluent quality parameters by using influent quality parameters of the WWTP. according to the literature reviews, these approaches were mostly used in predicting daily average parameters and, there were no studies including all three types of daily, weekly, and monthly average. Therefore, in the present study, we compare the efficiency of ANN

¹ Corresponding Author: Email: mtaalami@tabrizu.ac.ir

approach in simulating daily, weekly and monthly data on average of effluent quality parameters (BOD₅, COD and TSS) of Tabriz Wastewater Treatment Plant.

2-Methodology:

2-1-Case study (Tabriz Wastewater treatment plant):

The Tabriz Wastewater treatment process consists of two primary and secondary treatment stages. The first stage is physical treatment, and the latter is biological treatment and finally disinfection. The datasets used in this research included BOD₅, COD, TSS and PH parameters (daily, weekly and monthly) of influent of wastewater treatment plant as independent parameters and BOD₅, COD and TSS parameters (daily, weekly and monthly) of effluent of Tabriz wastewater treatment plant as dependent parameters. The data collected for daily and weekly average is assembled from March. 2009 till Nov. 2017 and the dataset for monthly average is gathered from 2002 up to Nov. 2017. 75% of the data were obtained for training dataset while 25% of the data were classified for the testing dataset. The data is normalized with mapminmax command in MATLAB ready code.

2-2-Artificial Neural Network:

One of the most common type of ANN is Multi-Layer Perceptron that consists of three typical layers: (I) input layer, (II) hidden layer and (III) output layer [7]. To simulate the effluent quality parameters of Wastewater Treatment Plant, a Multi-Layered Perceptron (MLP) Neural Network model with one hidden layer, different number of neurons and for mapping the information from the input layer to the hidden layer of the sigmoid tangent function and for mapping information from the hidden layer to the output layer, linear stimulator was used. The Levenberg-Marquardt (LM) algorithm was used to train Multi-Layer Perceptron Network and the maximum number of repetitions in the network training process was considered 1000. The number of neurons in the hidden layer is determined by trial and error in order to find the model with the lowest error value from 1 to 20 neurons.

2-3-Support Vector Machine:

The SVM algorithm can be used wherever it is necessary to identify patterns or classify objects into specific classes. Unlike most neural networks, SVM networks consider the operational risk as the objective function and calculate its optimal value instead of reducing the modeling or classification error [8]. In order to model the effluent quality of Tabriz wastewater treatment plant, RBF kernel was used.

2-4-Multiple Linear Regression:

The Multiple linear regression is used to model the relationship between descriptive and response variables by placing a linear formula for the observed data. According to this feature, the MLR method has been used in various environmental studies [9].

2-5-Model Performance Criteria:

In this study, the most common criteria consist of correlation coefficient (R), determination coefficient (DC) [10], root mean square error (RMSE) have been used.

$$R = \frac{\sum_{i=1}^N (x_i - \bar{x})(y_i - \bar{y})}{\sqrt{\sum_{i=1}^N (x_i - \bar{x})^2 \sum_{i=1}^N (y_i - \bar{y})^2}} \quad (1)$$

$$DC = 1 - \frac{\sum_{i=1}^N (x_i - y_i)^2}{\sum_{i=1}^N (x_i - \bar{x})^2} \quad (2)$$

$$RMSE = \sqrt{\frac{\sum_{i=1}^N (x_i - y_i)^2}{N}} \quad (3)$$

3-Results and discussion:

3-1-Artificial neural network method:

The modeling results for daily average data show that ANN model in predicting BOD_{eff} performs better than COD_{eff} and TSS_{eff} according to R, RMSE and DC values of testing datasets which is 0.82, 3.93, 0.676 for BOD_{eff}, 0.788, 6.206, 0.61 for COD_{eff} and 0.7, 3.03, 0.48 for TSS_{eff}, respectively. The quality parameters obtained from the Neural Network are in good agreement with the observed values.

According to the values of R, RMSE and DC of testing dataset of weekly average, Neural Network model in predicting BOD_{eff} parameter is 0.84, 3.127 and 0.703, 0.82, 4.8 and 0.68 in predicting COD_{eff} and 0.78, 2.69 and 0.622 in predicting TSS_{eff} parameter. Therefore, the performance of Neural Network model in predicting BOD_{eff} is better than COD_{eff} and COD_{eff} is better than TSS_{eff}.

The performance of the Neural Network model in predicting monthly BOD_{eff}, COD_{eff} and TSS_{eff} parameters, is acceptable due to R, RMSE and DC of testing dataset of monthly average which is 0.87, 2.86 and 0.76 for BOD_{eff}, 0.859, 4.51 and 0.715 for COD_{eff} and 0.8, 2 and 0.63 for TSS_{eff}, respectively. This model in predicting BOD_{eff} has better performance than COD_{eff} and in predicting COD_{eff} has better performance than TSS_{eff}. The quality parameters obtained from the

neural network are in good agreement with the observed values.

3-2-Support Vector Machine method:

According to the results of Support Vector Machine model for daily average data, the model in predicting BOD_{eff} has better performance than COD_{eff} and in predicting COD_{eff} has better performance than TSS_{eff} due to R, RMSE and DC values of testing stage which are 0.82, 3.93 and 0.676 for BOD_{eff} , 0.79, 6.18 and 0.617 for COD_{eff} and 0.69, 3.06 and 0.476 for TSS_{eff} , respectively.

According to R, RMSE and DC of testing dataset of weekly average, the support vector machine model in predicting BOD_{eff} has 0.817, 3.33 and 0.66 values, in predicting COD_{eff} has 0.8, 5.18 and 0.63 values and in the TSS_{eff} parameter prediction has 0.78, 2.75 and 0.604 values, respectively. Therefore, the performance of the support vector machine model in predicting BOD_{eff} is better than COD_{eff} and in predicting COD_{eff} is better than TSS_{eff} . The quality parameters obtained from the support vector machine are in good agreement with the observed values.

The performance of the Support vector machine model in estimating the monthly BOD, COD and TSS parameters of the effluent quality of wastewater treatment plant is acceptable according to R, RMSE and DC values of testing dataset which is 0.88, 2.8 and 0.77 for BOD_{eff} , 0.86, 4.38 and 0.73 for COD_{eff} and 0.79, 2.03 and 0.62 for TSS_{eff} , respectively. The support vector machine model in predicting BOD_{eff} performs better performance than COD_{eff} and in predicting COD_{eff} performs better than TSS_{eff} .

According to the results, ANN and SVM methods have good performance in predicting the effluent quality parameters of Tabriz wastewater treatment plant on a daily, weekly and monthly average. Both methods in modeling monthly dataset are better than weekly and daily.

3-3-Multiple Linear Regression:

In order to investigate the results of ANN and SVM methods with other methods, Multiple Linear Regression method was used, the results show that Artificial Intelligence methods are superior to the mentioned method.

4-Conclusion:

Artificial Intelligence techniques is an alternative to linear methods. In this research, the capability of Support Vector Machine and Artificial Neural Network methods in simulation of BOD_{eff} , COD_{eff} and TSS_{eff} parameters of daily, weekly and monthly data on average of Tabriz wastewater treatment plant were evaluated. According to the results, both methods perform the best performance in modeling the effluent quality

parameters of Tabriz wastewater as a monthly basis. The superiority of Support Vector Machine model in comparison with Artificial Neural Network model in simulation of BOD_{eff} and COD_{eff} parameters of daily and monthly average and the superiority of Artificial Neural Network model in comparison with Support Vector Machine model in simulation of BOD_{eff} , COD_{eff} and TSS_{eff} parameters of weekly average and TSS_{eff} parameter of daily and monthly average with the highest accuracy and least error in the testing. The MLR method was used in order to investigate the results of ANN and SVM methods with other methods, which shows the superiority of Artificial Intelligence methods over the mentioned method.

References:

- [1] E. Yel, S. Yalpir, Prediction of primary treatment effluent parameters by Fuzzy Inference System (FIS) approach, *Procedia Computer Science*, 3 (2011) 659-665.
- [2] Y.-S.T. Hong, M.R. Rosen, R. Bhamidimarri, Analysis of a municipal wastewater treatment plant using a neural network-based pattern analysis, *Water research*, 37(7) (2003) 1608-1618.
- [3] F.S. Mjalli, S. Al-Asheh, H. Alfadala, Use of artificial neural network black-box modeling for the prediction of wastewater treatment plants performance, *Journal of Environmental Management*, 83(3) (2007) 329-338.
- [4] H. Türkmenler, M. Pala, Performance Assessment of Advanced Biological Wastewater Treatment Plants Using Artificial Neural Networks, (2017).
- [5] M.M. Hamed, M.G. Khalafallah, E.A. Hassanien, Prediction of wastewater treatment plant performance using artificial neural networks, *Environmental Modelling & Software*, 19(10) (2004) 919-928.
- [6] V. Nourani, G. Elkiran, S. Abba, Wastewater treatment plant performance analysis using artificial intelligence—an ensemble approach, *Water Science and Technology*, 78(10) (2018) 2064-2076.
- [7] M. Zeinolabedini, M. Najafzadeh, Comparative study of different wavelet-based neural network models to predict sewage sludge quantity in wastewater treatment plant, *Environmental monitoring and assessment*, 191(3) (2019) 163.
- [8] V. Nourani, *Basics of Hydroinformatics*, Tabriz University Press. (In Persian), 2015.
- [9] A.E. Tümer, S. Edebalı, Prediction of wastewater treatment plant performance using multilinear regression and artificial neural networks, in: *2015 International Symposium on Innovations in Intelligent Systems and Applications (INISTA)*, IEEE, 2015, pp. 1-5.
- [10] J.E. Nash, J.V. Sutcliffe, River flow forecasting through conceptual models part I—A discussion of principles, *Journal of hydrology*, 10(3) (1970) 282-290.